



**Roosevelt Irrigation District**

103 W Baseline Rd, Buckeye, AZ 85326

Phone: (623) 386-2046      Email: [sgarcia@rooseveltirrigation.org](mailto:sgarcia@rooseveltirrigation.org)

April 23, 2026

**ADDENDUM NO. 1**

**PROJECT: ADOT Loop 303, Package 1 & Package 2 Relocations**

TO ALL CONTRACTORS:

Be advised of the additions, clarifications and/or changes to the above-referenced Invitation to Bid as stated in the following Addendum.

1. The bid closing date is extended to May 8, 2026 at 11:00 AM local time.
2. Questions and Answers

Questions	Answers
1. Can Stantec send CAD files	CAD files will be provided to the selected contractor
2. Are schedule days in working days or include weekends and/or holidays?	Calendar Days, which per ADOT agreement are defined as days besides Saturday and Sunday and any ADOT recognized holidays.

**Roosevelt Irrigation District**  
**ADOT Loop 303, Package 1 & Package 2 Relocations**  
**ADDENDUM NO. 1**  
 April 23, 2026

<p>3. Does the contract include liquidated damages</p>	<p>Per RID contract documents Section C-520 <i>Agreement Between Owner and Contractor for Construction Contract</i> – Subsection 4.05:</p> <p>Contractor and Owner recognize that time is of the essence as stated in Paragraph 4.01 above and that Owner will suffer financial and other losses if the Work, including any phased Contract Times, Milestones, Substantial Completion, and final completion, is not achieved within the required Contract Times, as duly modified. The parties also recognize the delays, expense, and difficulties involved in proving the actual loss suffered by Owner if the Work is not completed on time. Accordingly, instead of requiring such proof, Owner and Contractor agree that Owner, at its sole and exclusive option, may seek as liquidated damages for delay (but not as a penalty).</p>
<p>4. Can the contractors see the agreement between RID and ADOT.</p>	<p>Yes, a redacted agreement will be shared.</p>
<p>5. Can the contractors see the ADOT plans.</p>	<p>Yes, the ADOT plans will be shared.</p>
<p>6. Can the contractors see the ADOT Geotechnical Report.</p>	<p>Yes, the Geotech will be shared.</p>
<p>7. Is ADOT going to shut down road crossings.</p>	<p>Per ADOT Specs: The RID contractor shall develop traffic control plans for any irrigation relocation work impacting traffic flows within the project limits in accordance with Subsection 104.04 of the ADOT specifications. The RID contractor shall submit the traffic control plans to the contractor for coordination and to the Engineer for review and approval.</p>
<p>8. Is ADOT going to grade the site first.</p>	<p>ADOT is going to grade the site first. If the contractor wants to work prior to ADOT grading, approval from ADOT must be obtained.</p>
<p>9. Is ADOT going to want the spoils?</p>	<p>They have not indicated that at this time. Assume spoils will be hauled offsite and disposed.</p>
<p>10. Is the Cotton Lane/Loop 303 crossing on P-19 a jack and bore.</p>	<p>No, it is an encased crossing but the road will be shut down in pieces so that it can be installed via trenching.</p>
<p>11. Is the carrier pipe inside of the steel casing fusible PVC or HDPE?</p>	<p>Carrier pipe shall be DR25 C900 PVC joined via fusion. Pipe installation and fusion shall conform to AWWA C605 (current revision) and the manufacturer's instructions.</p>
<p>12. Does the bypass bid item include both installation and removal of the bypass.</p>	<p>Yes.</p>